

JOHNSON COUNTY FLEET FACILITY
JOHNSON COUNTY, IA
AXC 220201

ADDENDUM 01
DATE: MAY 30, 2023

SEALS:

This Seal Covers All Items included in Addendum 01



CONTRACTOR CLARIFICATIONS:

1. Q: Will recycled modified subbase be allowed if meeting specifications?
A: Yes, the use of recycled modified subbase is allowed as long as it meets specifications.
2. Q: Would you consider utilizing CD baskets in-lieu of the matting of bar?
A: Yes, the use of CD baskets will be allowed in-lieu of bar 12" o.c. If CD baskets are utilized, a jointing plan must be submitted and approved that includes the placement of baskets near the edge of pavement or the use of matt bar along the outer 10' edge of pavement.
3. Q: What size of rebar should be placed at 12" o.c.?
A: #4 Rebar.
4. Q: Is Striping and Signage needed on this project.
A: No pavement marking or signage needed.

END OF ADDENDUM 01